

HOSE RACK ASSEMBLIES



3200-3300 Series

2 1/2" X 1 1/2" HOSE RACK ASSEMBLY

Series 3200 and 3300 Hose Rack Assemblies permit one man operation and provide immediate means of fire control. These units are capable of delivering the nationally recognized standard of 100 GPM at 65 P.S.I. at the nozzle and are rated for Class II and Class III Service under NFPA/FEMA Class of Service.

STANDARD EQUIPMENT:


No. 3401- 1 1/2" Single Jacket Lined Hose - FM
No. 3440- 1 1/2" Cast Brass Coupling
No. 3460- 1 1/2" Industrial Fog Nozzle U/L
No. 5045- 2 1/2" Cast Brass Angle Valve U/L
No. 5735- 2 1/2" Cadmium Plated Escutcheon


No. 3355- Red Enamel Pin Rack U/L No. 3366- 2 1/2" Cast Brass Nipple


No. 7245- 2 1/2" X 1 1/2" Cast Brass Reducer

Figure	Hose	Hose	Hose	Valve	Dimensions				
No.	Length	Diameter	Туре	Size	Α	В	С	D	AN
Basic Unit As Regularly Furnished (above)									
3205	50'	1 1/2"		2 1/2"	17 7/8	23	4 1/8	5	20 1/16
3207	75'	1 1/2"	POLY	2 1/2"	17 7/8	23	4 1/8	5	20 1/16
3210	100'	1 1/2"	LINED	2 1/2"	17 7/8	25	4 1/8	5	20 1/16
3212	125'	1 1/2"	HOSE	2 1/2"	17 7/8	28	4 1/8	5	20 1/16

Basic Unit with Red Enamel Rack, Chrome Plated Brass Fittings and Chrome Plated **Rough Brass Valve** 3305 50' 1 1/2" 2 1/2" 17 7/8 23 4 1/8 5 20 1/16 75' **POLY** 23 4 1/8 5 20 1/16 3307 1 1/2" 2 1/2" 17 7/8 17 7/8 25 5 20 1/16 3310 100' 1 1/2" LINED 2 1/2" 4 1/8 3312 125' 1 1/2" HOSE 2 1/2" 17 7/8 4 1/8 20 1/16







FEMA/NFPA CLASS OF SERVICE

Class 1 - Fire Service Only

Class 2 - Occupant Use

Class 3 - Fire Service or Occupant Use

NOTE

When specifying rack units consider NFPA Phamphlet No. 14 suggests and recommends the use of lined hose in lengths not exceeding 100' (30.0M) for interior hose cabinets.